



WYANDOTTE NATION TRIBAL WELL
OPERATIONAL MONTHLY REPORT
GROUND WATER SYSTEM

PWS ID # 062005883

ADDRESS

64700 E

HWY

60

CITY

WYANDOTTE

OK

74370

PHONE # 918-678-2297

SERVED

MONTH

January

2026

	WATER PUMPED		WATER PUMPED					comment	water table	water pressure	Chlorine Reading After Change out
DATE 2026 Jan	1000 GALLONS	1000 GALLONS									
	PER DAY	PER DAY	CHLORINE READINGS								
	well 1	well 2	TCR001	TCR003	TCR005	well 1 entry	well 2 entry				
LAST MONTH	151315	110926							(w2)	(w2)	
1	Holiday										
2	151346	110973	0.41	0.25	0.30	0.70	0.82		210	45	
3											
4											
5	151388	111008	0.31	0.49	0.28	0.61	0.67		210	45	
6	151398	111023	0.34	0.48	0.28	0.54	0.43		210	44	
7	151409	111036	0.40	0.48	0.32	0.66	0.99		210	44	
8	151420	111060	0.38	0.34	0.27	0.53	0.81		210	45	
9	151430	111072	0.42	0.41	0.28	0.54	0.73		210	44	
10											
11											
12	151472	111117	0.32	0.31	0.28	0.56	0.89		210	44	
13	151483	111130	0.33	0.29	0.37	0.61	0.92		210	44	
14	151503	111142	0.31	0.38	0.33	0.59	0.69		210	44	
15	151514	111161	0.35	0.42	0.32	0.64	0.67		210	45	
16	151529	111178	0.40	0.30	0.34	0.62	0.75		210	44	
17											
18											
19	Holiday										
20	151592	111236	0.48	0.53	0.33	0.74	0.78		210	44	
21	151603	111260	0.45	0.47	0.35	0.86	0.99		210	45	
22	151614	111272	0.54	0.32	0.27	0.78	0.89		210	45	
23	151639	111296	0.52	0.57	0.35	0.72	0.76		210	45	
24											
25											
26	Office	Closed	Snowday								
27	151713	111380	0.47	0.48	0.34	0.73	0.89		210	44	
28	151734	111404	0.48	0.43	0.36	0.74	0.60		210	45	
29	151745	111416	0.43	0.34	0.35	0.83	0.97		210	45	
30	151766	111429	0.48	0.48	0.27	0.62	0.89		210	45	
31											
TOTAL	451000	503000									
AVG.	15033	16767									

SIGNED

Jesus Pulido

1/30/2026

TITLE Water Operator, Utilities Department