



WYANDOTTE NATION TRIBAL WELL
MONTHLY OPERATIONAL REPORT
GROUND WATER SYSTEM

PWS ID # OK2005883

ADDRESS **64700 E HWY 60**

STATE **OK**

ZIP **74370**

PHONE # 918-678-2297

POPULATION SERVED

MONTH

March

2026

DATE 2026 MARCH	WATER PUMPED		CHEMICALS USED						
	1000 GALLONS PER DAY		CHLORINE AND RESIDUALS			water pressure	COMMENTS	Water Table	Reading after changing out Chlorine
		flush	entry point	CHLORINE READINGS					
	WELL 3			recharge					
LAST MONTH	41159		(W3)		(H)				
1									
2	41195		0.31		0.53	63		310	
3	41205		0.33		0.56	63		310	
4	41218		0.33		0.66	64		320	
5	41228		0.31		0.62	63		310	
6	41241		0.32		0.62	64		330	
7									
8									
9	41274		0.33		0.58	64		330	
10	41284		0.36		0.57	62		320	
11	41297		0.63		0.54	63		330	
12	41307		0.54		0.27	63		325	
13	41320		0.89		0.60	63		330	
14									
15									
16	41365		0.32		0.53	63		310	
17	41381		0.31		0.53	64		348	
18	41395		0.28		0.55	63		310	
19	41411		0.35		0.52	63		325	
20	41425		0.23		0.53	63		330	
21									
22									
23	41476		0.35		0.57	64		310	
24	41490		0.38		0.84	64		310	
25	41507		0.33		0.83	64		310	
26	41520		0.36		0.87	64		330	
27	41533		0.29		0.86	64		328	
28									
29									
30	41569		0.28		0.84	64		320	
31	41579		0.29		0.62	63		340	
TOTAL	420000								
AVG.	13548								

SIGNED **Jesus Pulido** 3/31/2026

TITLE Water Operator, Utilities Department